## Acidic Condensation Neutralization Kit

Item						
1	1 1" Schedule 40 PVC FM x FM Coupling 2 3" Schedule 40 PVC CAP (Modified) 3 3" Schedule 40 DWV-PVC Pipe 4 3"x3"x2" 1/4Bend with Side Outlet					
2						
3						
4						
5	<sup>3</sup> " MIP Polypropylene Screen					
6	14 Gauge 13/16" Painted Uni-Strut					
7	Zinc Coated Uni-Strut Clamp	2				
8	2" Fitting Clean out with Flush Cleanout Plug	1				
9	Limestone Formulated Mix	_				
10	3" Street Elbow	1				


	F		· cc	Condensing	O	C	A
ı.	FOR HISE ON	HIAN E	·miciency	C.Ongensing	t-ac	FIREC	Anniiances
	1 01 030 011	1 11911 -	. I I I O I O I I O y	Condensing	Ous	i ii ca	, ipplialices

- Neutralizes flue gas condensation to a "Neutral 7.0" PH Level For Safe Disposal to drain and sewer
- Compliance with Michigan Plumbing Code Sections 803 & 314
- All connections prepaired with low "VOC" primer and PVC-Glue
- Active agent is crushed limestone & pelletized lime formulated mix
- Eliminates damage to concrete floors and cast iron drainage piping

\*\*Dimensions are Approximate\*\*

\*\*Patent Pending Design\*\*

Made in the U.S.A





## Model: BKI-6000

BTU Capacity: Up to 6000 MBH

Est. Weight: 21 lbs

www.bkiindustries.com

## BKI Industries, Inc

P.O. Box 256 Walled Lake, MI 48390

Phone: 248-977-5550

Fax: 248-438-1674

Approved by: Scale: None

Date: 7-17-12 Revision: 1.0